



Overview table reference methods Concrefy

Versionnumber:	1.1			
Versiondate:	31 May 2021			
material	test	scope nr.	standard	execution (conform / equivalent to)
concrete	Determination of the density Determination of the compressive strength Determination of the penetration depth of water under pressure Determination of the penetration depth by capillair absorption Determination of the water absorption Determination of the tensile splitting strength	1 2 3 4 5 6	NEN-EN 12390-7 NEN-EN 12390-3 NEN-EN 12390-8 CUR/PBV Aanbeveling 63 NBN-B 15-215 NEN-EN 12390-6	conform conform conform conform conform conform
mortar	Determination of the flexural bending strength (threepoint-bending test) Determination of the compressive strength	7 8	NEN-EN 196-1 NEN-EN 13892-2 NEN-EN 1015-11 NEN-EN 196-1 NEN-EN 13892-2 NEN-EN 1015-11	conform conform conform conform conform conform
steel fibre concrete	Determination of the flexural bending strength (threepoint-bending test)	9	NEN-EN 14651:2005+A1 (exclusief §7.2)	conform
concrete slabs	Determination of the dimensions Determination of the flexural bending strength (threepoint-bending test) Determination of the abrasion resistance Determination of the mass loss after freeze thaw simulation	10 11 12 13	NEN-EN 1339 NEN-EN 1339 NEN-EN 1339 NEN-EN 1339	conform conform conform conform
concrete paving blocks	Determination of the dimensions Determination of the tensile splitting strength Determination of the abrasion resistance Determination of the mass loss after freeze thaw simulation	14 15 16 17	NEN-EN 1338 NEN-EN 1338 NEN-EN 1338 NEN-EN 1338	conform conform conform conform
concrete curb units	Determination of the dimensions Determination of the flexural bending strength (threepoint-bending test) Determination of the abrasion resistance Determination of the mass loss after freeze thaw simulation	18 19 20 21	NEN-EN 1340 NEN-EN 1340 NEN-EN 1340 NEN-EN 1340	conform conform conform conform
slope elements of concrete	Determination of the compressive strength Determination of the water absorption Determination of the saturated density	22 23 24	NEN 7024-2 / NEN 7024-3 NEN 7024-2 / NEN 7024-3 NEN 7024-1	conform conform conform
aggregates for production of concrete	Determination of the particle size distribution Determination of the particle density and waterabsorption (particle size <32 mm) Determination of the content of lightweight contaminants Determination of shell content Determination of fine material; sand equivalent test Determination of the freeze thaw resistance	25 26 27 28 29 31	NEN-EN 933-1 NEN-EN 1097-6 NEN-EN 1744-1 (§14.2) NEN-EN 933-7 NEN-EN 933-8 NEN-EN 1367-1	conform conform conform conform conform conform



Overview table reference methods Concrefy

Versionnumber:	1.1			
Versiondate:	31 May 2021			
material	test	scope nr.	standard	execution (conform / equivalent to)
granulair material	Determination of the constituents of coarse recycled aggregates Determination of the increase of CBR value Determination of the constituents of granulate Determination of the particle shape - flakiness index Determination of the resistance to fragmentation (LA-test method) Determination of the laboratory reference density and water content; 1-point Proctor test	30 32 33 34 35 36	NEN-EN 933-11 NEN-EN 14227-2 Annex D RAW 2010 proef 35 NEN-EN 933-3 NEN-EN 1097-2 NEN-EN 13286-2 Annex B	conform conform conform conform conform conform
reinforcing steel	Determination of the tensile strength, the 0.2%- yield stress and elongation at maximum load (bars) Determination of the geometrical characteristics Determination of the tensile strength, the 0.2%- yield stress and elongation at maximum load; tensile load (welded bars) Determination of the shear strength; shear test Determination of fatigue strength; high frequency cyclic loading test (bars) Determination of fatigue strength; high frequency cyclic high frequency cyclic loading test (welded bars)	37 38 39 40 41 42	NEN-EN 15630-1 / NEN-EN ISO 6892-1 NEN-EN 15630-1 NEN-EN 15630-2 / NEN-EN ISO 6892-1 NEN-EN 15630-2 / NEN-EN ISO 6892-1 ISO 15630-1 (§ 8) ISO 15630-2 (§ 8)	conform conform conform conform conform conform
reinforcement couplers	Determination of the tensile strength, the 0.2%- yield stress and elongation at maximum load (bars) Determination of slip after a low frequency cyclic loading test Determination of fatigue strength; high frequency cyclic loading test, testing in air Determination of elongation after alternating tensile and compression loading test (category S1); low frequency loading test Determination of elongation after alternating tensile and compression loading test (category S2); low frequency loading test Determination of dynamic strength; low frequency cyclic loading test	43 44 45 46 47 48	ISO 15835-2 (§ 5.3) ISO 15835-2 (§ 5.4) ISO 15835-2 (§ 5.5) ISO 15835-2 (§ 5.6.1) ISO 15835-2 (§ 5.6.2) California Test 670 (§ F.1.)	conform conform conform conform conform conform
aggregates for production of concrete	Determination of the content of chloride Determination of the degree of pollution caused by strong swelling clay minerals Determination of the content of fulvic acid Determination of the humus content Determination of the presence of stain causing iron and vanadium compounds Determination of the content of fine material (fraction 0 / 2); methylene blue test	49 50 51 52 53 54	NEN-EN 1744-1 (§7) NEN 5941 (1988) NEN-EN 1744-1 (§15.2) NEN-EN 1744-1 (§15.1) NEN 5923 (1988) NEN-EN 933-9	equivalent to conform conform conform conform conform conform
bituminous mixtures	Determination of the thickness of a bituminous layer Determination of the sample density Determination of the content of soluble binder Determination of the particle size distribution Determination of the mixture density Determination of the content of pores in bituminous materials	55 56 57 58 59 60	NEN-EN 12697-36 NEN-EN 12697-6 procedure B NEN-EN 12697-1 Annex B1.3/B.3/C.3 NEN-EN 12697-2 + A1 NEN-EN 12697-5 methode C NEN-EN 12697-8	conform conform conform conform conform conform